



STD- 07184, Office - 255093, C.O – 252088, President – 251720

OFFICE OF THE MUNICIPAL COUNCIL, BHANDARA.

Email- bhandaranagarpalika@gmail.com

No. : - MCB/CO/ 477 /2023

Date: - 07/02/2023

FIRE SAFETY CERTIFICATE

Certified that Principal of St. Mary's School, Bhandara situated at St. Mary's Nagar Khat Road, Bhandara Dist- Bhandara. Comprised of G+3 occupied by St. Mary's School, run by St. Mary's Education, Health and Multipurpose Society, Nagpur, have completed with the fire prevention and fire safety requirements in accordance with Fire Safety rule of Maharashtra Fire Safety Regulation, 2006 and verified by the officer concerned of Fire Service on 01/02/2023 in the presence of Vice Principal Miss. Yana Masih, R/O. Khat Road, Bhandara of St. Mary's School, Bhandara and that the said school premises is fit for the occupancy up to classes X. With effect from 16/01/2023 to 15/01/2024 for a period of One Year in accordance with rule & subject to compliance of specific conditions as appended :-

- 1) School has instructed to get all the fire safety equipments inspected through licensed agency in every six month i.e. January to June and July December and get Form B from Licensed agency. One copy of which has to be submitted mandatorily to the Municipal Council, Bhandara.
- 2) Fire extinguishers equipments 4 Fire Buckets with stand of 01 Number, BC (Co2) of 4.5 kg of 01 Number, ABC (DCP) of 6 kg in 07 Numbers ABC (DCP) of 9 kg in 01 Number and BC (DCP) of 5 kg in 01 Number were installed and these are valid till 15/01/2024.
- 3) It is also certified that Old Fire Extinguishers Equipments Servicing, Refilling, Maintenance are in good Conditions to run the School.



(Vinod Badhao)

Chief Officer
Municipal Council, Bhandara.